



Certificate of Analysis

NO: CST180

No	PROPERTIES	UNIT	RESULT	Test Method
1	Density@15°C	Kg/m ³	990 max	ASTM D1298
2	Kinematic viscosity	Cst	180	ASTM D445
3	Flash point	°C	60 min	ASTM D93
4	Pour point	°C	30	ASTM D97
5	Carbon residue	%m	20	ASTM D4530
6	Ash	%m	0.15	ASTM D482
7	Water	%	1	ASTM D95
8	Sulphur	%m	3.0	ASTM D4294
9	Vanadium	Mg/kg	500	ASTM D1548
10	Aluminum & silicon	Mg/kg	80	ASTM D5184
11	Total sediment	%m	0.1	ASTM D4870
12	Acid number	Mg KOH/g	3	ASTM D664
13	CCAI	-	860	-